

Questions & Answers  
OConnor Oil Co Bulk Plant  
54901-1201-05  
02-71-259386

Question:

There is an existing fence in the area of the proposed excavation which will need to be removed in order to reach the 8' excavation depth.

Should our bid include the cost of repairing/replacing this fence?

Answer: No. The fence is in disrepair and will not be replaced.

Question:

What should be the construction of the sump?

Answer: A 4 inch sump screened from 3 to 8 feet will be constructed in the deeper excavation. The location of the sump will be pre-approved by the Commerce project manager.